

Efectis

EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovaarı OSB Mahallesi Fırat Caddesi No: 18
Dilovaarı KOCAELİ/TÜRKİYE
www.effectis.com

TEST CERTIFICATE

Certificate Nr: EEA – 2000 – 0054

The related resistance-to fire-test was carried out at **Efectis Era Avrasya Test Laboratories** on 13.03.2020 in accordance with EN 1634-1:2014 + A1:2018 standard for the product as described below:

“WR FSD 60” FIRE RESISTANT STEEL SECTIONAL DOOR

Vertical VL

FIRE RESISTANCE CLASSIFICATION	
Direction: Supporting components fixed on the face of the supporting wall on the unexposed side	E180, EW180, EI ₂ 30, EI ₁ 30

Placed on the market by

WHITE ROSE MOTOR SAN. VE OTOMASYON TİC. LTD. ŞTİ.
OSB Mah. 9. Cad. No:1 Merkez/KARAMAN/TURKEY

And Produced In the Factory

WHITE ROSE MOTOR SAN. VE OTOMASYON TİC. LTD. ŞTİ.
OSB Mah. 9. Cad. No:1 Merkez/KARAMAN/TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA – 20– 069**. This certificate is initially valid until 13th March 2021 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.



Ali BAYRAKTAR
Laboratory Manager
19.03.2020

